


RDH

Energy Efficiency Tune-Ups for Mid- to High-Rise Residential Buildings

→ Graham Finch, MAsC, P.Eng




BCBEC Conference and AGM - September 21, 2011

RDH

Overview

- Summary of a mid- to high-rise Multi-Unit Residential Building (MURB) energy study
- Measured energy savings from full building enclosure rehabilitations
- Strategies to retrofit and improve the energy efficiency of existing MURBs




Multi-Unit High-Rise Residential Building Energy Study

- Energy consumption of over 60 mid- to high-rise Multi-Unit Residential Buildings (MURBs)
 - Constructed between 1974 and 2002
- Half of study buildings underwent a full-scale building enclosure rehabilitation
 - Allows for the assessment of actual energy savings from enclosure performance
- Pre- and post-rehabilitation R-values, airtightness characteristics analyzed with a decade of daily/month gas & electricity data.
- Other building performance characteristics as the result of the enclosure improvements and other HVAC changes were also assessed.




Summary: MURB Energy Consumption Intensity

Average 39 Buildings = 213 kWh/m²/yr




→ Total Energy Consumption vs Year of Construction




→ Typical Energy Consumption: 1980s-1990s MURB

Average of 11 typical study buildings - Total 206 kWh/m²/yr




Typical Energy Consumption: Post 2000/Modern MURB

Average of several typical modern MURBs– Total >222 kWh/m²/yr



Greenhouse Gas Emissions: Average of Study MURBs



→ Addressing Energy Efficiency in MURBs


- MURB energy consumption is predominantly influenced by space-heating
 - Building enclosure thermal performance is typically poor (<R-3)
 - Walls have low effective R-values due to thermal bridging, steel framing, exposed concrete slabs etc.
 - Window R-values are very low, and are the largest source of heat loss
 - Air-Leakage through enclosure, and through operable windows is high
 - Make-up air unit gas consumption is high due to pressurized corridor ventilation flow rate and high set-point temperatures – yet very little of this air makes it into the suites
 - Fireplace gas consumption is high as heating efficiency is poor and little incentive to conserve as usage appears “free”

→ MURB Energy Simulations : The Potential

Energy Model Calibrated with Billing Data and Building Enclosure and HVAC Characteristics


Scenario	Simulation Inputs
Baseline:	• Walls effective R-3.6
Pre-Rehab	• Windows single glazed U = 0.7, SC = 0.67 • Air tightness “Tight – High Average”, 0.15 cfm/ft ² • Make-up air temperature set-point 68° F • No heat recovery
Good:	• Walls effective R-10
Target Performance	• Windows double glazed, argon fill, low-e, low conductive frame; U = 0.27, SC = 0.35 • Air tightness “Tight – Low Average”, 0.05 cfm/ft ² • Make-up air temperature set-point 64° F • No heat recovery • No Fireplaces
Best:	• Walls effective R-18.2
Green Design Performance	• Windows triple glazed, argon fill, low-e, low conductive frame; U = 0.17, SC = 0.23 • Air tightness “Very Tight”, 0.02 cfm/ft ² • Make-up air temperature set-point 60° F • 80% Heat Recovery • No Fireplaces

→ Potential for MURB Space Heat Consumption in Vancouver



→ Impact of Space Heat Energy on Total Energy Consumption

- Can reduce energy by almost half with ventilation and enclosure upgrades only
- Further improvements from DHW, Lighting, Appliances, Controls etc.



Current Levels ~ 200 kWh/m²/yr

We can get to ~100 kWh/m²/yr

→ Energy Savings from Building Enclosure Rehabilitations

- Enclosure rehabilitations performed at study MURBs primarily to address moisture ingress damage
- Little incentive for owners to perform energy upgrades due to increased cost – a huge missed opportunity
- Full 100% re-cladding, insulating and new windows at all study MURBs
- Thermal improvements from: exterior insulation assemblies, improved detailing (i.e. cladding attachments), better windows (thermally broken, low-e etc.)
- Improved air-tightness characteristics during rehabilitation



→ Typical Rehabilitation Thermal Detailing


Pre-Rehabilitation




Post-Rehabilitation



Improvement in Overall Thermal Performance: R-value




Overall Effective R-value by Year of Construction






Energy Savings from Enclosure Rehabilitations

Average 14% Space-Heat Energy Savings & 8% Total Building Energy Savings




Calibrated Energy Model Predictions vs Actual Savings






→ Energy Retrofit Potential for Existing MURBs

- Findings from study identified several key components of MURBs which can be improved during enclosure rehabilitation work or as part of specific energy retrofits
 - Building enclosure upgrades
 - Mechanical ventilation system upgrades and tune-ups
 - Installation of better space-heating controls
 - Elevator & mechanical system retro-commissioning and upgrades
 - Lighting upgrades



→ Building Enclosure Improvements






→ Incremental Cost of Rehabilitation Energy Upgrades

- Energy savings from full enclosure rehabilitations will not pay for the rehab anytime soon, however...
- Incremental cost and energy savings analysis of the several retrofit measures was performed
 - In most buildings the incremental cost in reducing thermal bridging (i.e. more effective use of provided insulation) or adding extra insulation (i.e. 1-2") to the walls would have paid back over the life of the upgrade in energy savings
 - In most buildings the incremental cost for some higher performing window components (frames, IGUs) would have paid back over the life of the windows in energy savings
- Beneficial to model the potential for incremental energy efficiency improvements while performing building enclosure rehabilitation work

→ HVAC and Mechanical System Improvements




→ Ventilation Distribution and Air Flow within MURBs

Pressurized Corridor:

Design flow rate varies <30 cfm/suite in older buildings up to >130 cfm/suite post 2000s.

Actual flow rate making it into the suites less, often as low as 1/3 of supply.

Ventilation/IAQ problems were common in most study MURBs



→ Ventilation Make-up Air


- Gas used to temper ventilation by make-up air is single largest component of energy use in most MURBs
 - Regular service of make-up air units, burners, controls, filters etc. necessary for optimal energy performance
 - Dirty MAU filters found to reduce flow rate significantly affecting both energy consumption and IAQ
- Ventilation is for occupant health
 - Flow-rate should never be turned down, off, setback, or on a timer unless sufficient ventilation is actually being delivered to occupants within the suites (not corridors)
- Consider set-back of temperature & controls to do so
 - Typically temperature of 21C or higher set by strata or by maintenance contractors – large savings from lowering this.



Impact of Make-up Air Set point Temperature



Total Space Heat Energy Consumption (Gas & Suite Electric) - Vancouver



Domestic Hot Water Systems


- Average DHW Load in typical MURB, 12 GJ/suite/yr (~\$140/suite)
- Significant energy savings in MURBs where DHW system upgrades were performed during study period
- Mid-1980s continuous re-circulating DHW systems replaced with on-demand w/electric heat tracing in 2 study MURBs
 - Building 32 (135 suites), 50% reduction in DHW gas, savings of 1,285 GJ/yr (\$14,000/yr, \$104/suite)
 - Building 33 (165 suites), 64% reduction in DHW gas, savings of 2,200 GJ/yr (\$26,000/yr, \$160/suite)

→ Elevators and Controls


- Elevators rely on controls to be energy efficient
- Several of the 1980s-1990s MURBs within the study had AC-DC converters running continuously (timers were broken for several years, or not installed), resulting in significant energy waste
- Building 33 Elevator (2 cabs, mid-80s controls)
 - w/ Faulty Timer (122,000 kWh/yr, ~\$8,500/yr)
 - w/ Fixed Timer (46,000 kWh/yr, ~\$3,200/yr)
 - w/ new VVVF system (21,000 kWh/yr, ~\$1,500/yr)



→ In-Suite Space Heating and Ventilation



→ Impact of Fireplace Energy Consumption: Typical MURB




→ Individual Fireplace Sub-metering




- Gas for fireplaces on single utility meter paid for by strata as part of maintenance fees – not directly by users
- Sub-metering is recommended to encourage conservation
 - Thermal meters are available to monitor time of use
 - Pilot project within a study MURB estimated that after first year of sub-metering and shutting off pilot lights during summer – fireplace gas consumption was reduced by approximately half.
 - Cost of meter installation will be paid for by savings in few years
 - Sub-metering also found that 60% of the 138 occupants in same MURB leave pilot lights on year round, and 12 occupants use their fireplace regularly (i.e. to heat) over the summer.
 - Building wide pilot-light shutoff/lighting programs suggested
- Alternately replace on-off switches with thermostat and/or timer controls

Common Areas and Amenity Spaces



Pool/Jacuzzi gas at one study MURB – 2,500 GJ/yr.
Total gas for all hot water/ventilation air for same MURB– 5,000 GJ/yr

Parking Garages



RDH

www.rdhbe.com



Questions

gfinch@rdhbe.com